



Test Certificate

Nr.: **C2922T15-2 (English Version)**

Applicant **PANELES AISLANTES PENINSULARES, S.L.**
Polígono 505, parcela 62-B
16440 – MONTALBO (Cuenca)

Type of specimen **Sandwich panel with PIR core with commercial reference “Elastopir”.**
Manufacturer: Paneles Aislantes Peninsulares

Reference:

FRIGOPAP PIRB	FRIGOPAP +
FRIGOPAP E PIRB	FRIGOPAP + E
WALLPAP PIRB	WALLPAP +
COVERPAP PIRB	COVERPAP +

Test/s

- Test according to standard UNE-EN 13823:2012, “Reaction to fire tests for building products - Building products excluding floorings exposed to the thermal attack by a single burning item”
- Test according to standard UNE-EN ISO 11925-2:2011 “Reaction to fire tests - Ignitability of products subjected to direct impingement of flame - Part 2: Single-flame source test (ISO 11925-2:2010)”.

Test dates 07th-Oct-15 and 14th-Oct-15

Certificates of reports Test report Nr. 2922T15 (issued by AFITI-LICOF on 06th-Nov-15).
Classification report Nr. 2922T15-3 (issued by AFITI-LICOF on 16th-Apr-18).

Reaction to fire classification

B-s1,d0

Classification according to standard UNE-EN 13501-1:2007+A1:2010 “Fire classification of construction products and building elements-Part 1: Classification using data from reaction to fire tests”

Toledo, 29th January of 2019


Digitally Signed Document

Signed: David Sáez García
Technical Director of
Reaction to Fire Laboratory

This Test Certificate contains the English version only from the Spanish Test Certificate Report dated 16th-Apr-18. In case of doubt, the Spanish version Test Report prevails.

The results of this Certificate refer solely and exclusively to the specimens tested, and not to the product in general. The specified reports include important aspects of the test performance and development which have made it possible to obtain the aforementioned Reaction to Fire classification. This certificate should be used together with the referenced reports. Cancellation or modification of the aforementioned reports implies cancellation or modification of this certificate.